



Product Service

CERTIFICATE

No. Z2 083334 0049 Rev. 02

Model(s):

1000 V DC system voltage Single Glass modules:
 UL-xxxP-72, xxx= 330 to 360 in step of 5;
 UL-xxxP-60, xxx= 275 to 300 in step of 5;
 UL-xxxP-54, xxx= 245 to 270 in step of 5;
 UL-xxxP-48, xxx= 220 to 240 in step of 5;
 UL-xxxP-24, xxx= 110 to 120 in step of 5;
 1500 V DC system voltage Single Glass modules:
 UL-xxxP-72HV, xxx= 330 to 360 in step of 5;
 UL-xxxP-60HV, xxx= 275 to 300 in step of 5;
 UL-xxxP-54HV, xxx= 245 to 270 in step of 5;
 UL-xxxP-48HV, xxx= 220 to 240 in step of 5;
 UL-xxxP-24HV, xxx= 110 to 120 in step of 5;

Half cell 1000 V DC system voltage Single Glass modules:
 UL-xxxP-144, xxx = 335 to 375 W in step of 5;
 UL-xxxP-120, xxx = 280 to 310 W in step of 5;
 UL-xxxP-108, xxx = 255 to 280 W in step of 5;
 UL-xxxP-96, xxx = 225 to 250 W in step of 5;
 Half cell 1500 V DC system voltage Single Glass modules:
 UL-xxxP-144HV, xxx = 335 to 375 W in step of 5;
 UL-xxxP-120HV, xxx = 280 to 310 W in step of 5;
 UL-xxxP-108HV, xxx = 255 to 280 W in step of 5;
 UL-xxxP-96HV, xxx = 225 to 250 W in step of 5;
 xxx is standing for rated output power at STC.

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1000 V DC or 1500 V DC
Fire Safety Class:	Class C according to UL790.

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016

Production Facility(ies):

083334

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT